

DECLARATION OF PERFORMANCE
According to Construction Products Regulation EU No 305/2011
No FPP/FP-1922-1145

1. Unique identification code of the product-type:

Model(s): Ajax FireProtect, Ajax FireProtect Plus; Brand(s): AJAX

2. Intended use/es:

Fire safety, smoke detection indoor use

3. Manufacturer :

"AJAX SYSTEMS MANUFACTURING" LLC, S. Skliarenko Str., 5, Kyiv, 04073, Ukraine

4. Authorised representative:

AJAX SYSTEMS CYPRUS HOLDINGS LTD, Ifigeneias, 17, Strovolos, 2007, Nicosia, Cyprus

5. System(s) of AVCP:

System 1

6. Harmonised standard/s:

EN14604:2005

EN 14604:2005/AC:2008

Notified body :

1922 DEDAL, Attestation & Certification

7. Declared performance:

Essential characteristics	Performance	Harmonised technical specification EN14604:2005, EN 14604:2005/AC:2008
Nominal activation conditions /Sensitivity/ Response delay (response time) and Performance under fire conditions	pass	4.12, 5.2-5.6, 5.15, 5.17, 5.18, 5.20
	n.a.	4.18, 5.19
Operational reliability	pass	4.1, 4.2, 4.5-4.7, 4.9, 4.10, 4.13-4.19, 5.11, 5.16, 5.22-5.24
	n.a.	4.3, 4.4, 4.8, 4.11
Tolerance to supply voltage	pass	5.21
Durability of operational reliability and response delay: temperature resistance	pass	5.7, 5.8
Durability of operational reliability; vibration resistance	pass	5.12, 5.13