



Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

# CERTIFICATE

No: 000237/04

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we Kiwa FSS products certify that the product

**HS3128**

is in conformity with the following standard(s)

**EN 50131-10 June, 2014**

Alarm systems - Intrusion and hold-up systems - Part 10: Application specific requirements for Supervised Premises Transceiver (SPT)

**EN 50131-3 March, 2009**

Alarm systems - Intrusion and hold-up systems - Part 3: Control and indicating equipment

**EN 50131-6+A1 June, 2021**

Alarm systems - Intrusion and hold-up systems - Part 6: Power supplies

**EN 50136-2 August, 2013**

Alarm systems - Alarm transmission systems and equipment - Part 2: Requirements for Supervised Premises Transceiver (SPT)

**Digital Security Controls, a div. of Tyco Safety Products Canada Ltd.**

3301 Langstaff Road  
L4K 4L2 CONCORD  
Canada

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

**04-12-2026**

Signed on behalf of Kiwa FSS products

20 Jan 2023

**Ron Scheepers**  
Managing director



[www.certalarm.org](http://www.certalarm.org)

Registered in Brussels: CertAlarm AISBL, 1080 Brussels, Boulevard Edmond Machtens 180

This certificate and the annex(es) may only be copied completely and without any additions.

# CERTIFICATE

No: 000237/04 - Annex No 1

## Takes into account the following product:

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3128
- Hardware version: UA718 Rev. 03
- Software version: 1.4
- Serial number: N/A

## Variants:

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3128P
- Hardware version: UA718 Rev. 03
- Software version: 1.4
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3032
- Hardware version: UA718 Rev. 03
- Software version: 1.4
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3032P
- Hardware version: UA718 Rev. 03
- Software version: 1.4
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3248
- Hardware version: UA718 Rev. 03
- Software version: 1.4
- Serial number: N/A

- Product description: CIE
- Trademark: DSC/Tyco
- Type designation: HS3248P



Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

# CERTIFICATE

No: 000237/04 - Annex No 1

- Hardware version: UA718 Rev. 03  
- Software version: 1.4  
- Serial number: N/A

## The optional features of the specifications that are included in the product and test report:

The Model HS3032, HS3128 and HS3248 Control Panel is compliant to EN 50131-3:2009 Type B, EN 50131-6:2017 Type A, EN 50131-10, EN 50136-2:2013 ATS SP3 (dialer), SP4 (Ethernet), DP2 (dialer and Ethernet), DP3 (Ethernet and plug-in cellular) when installed in enclosure models HSC3020C or HSC3020CP. When HS3032, HS3128 or HS3248 Control panel is mounted in the plastic enclosure model HSC3020CP the final product model name is HS3032P, HS3128P or HS3248P.

Security grade: 3  
Security grade: 2: When HSM2HOST8 is added to HS3032, HS3128 or HS3248 (either external use in its own plastic enclosure or mounted in the control panel plastic enclosure HSC3020CP)  
Environmental class: II  
Equipment class: Fixed  
Power supply type: A

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2 (when HSM2HOST8 is added to HS3032, HS3128 or HS3248 (either external use in its own plastic enclosure or mounted in the control panel plastic enclosure HSC3020CP) or grade 3.  
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:  
TYCO INTERNATIONAL DE MEXICO S DE R.L. DE C.V.  
Antonio Meucci Yg Gonzalez Camarena 10002  
PARQUE INDUSTRIAL LA VENTANA  
87569, Matamoros  
Mexico

Product inspection location:  
AnB Rimex SA  
Rue de l'Abbaye 89  
4040 Herstal  
Belgium

[www.certalarm.org](http://www.certalarm.org)

Registered in Brussels: CertAlarm AISBL, 1080 Brussels, Boulevard Edmond Machtens 180

This certificate and the annex(es) may only be copied completely and without any additions.  
Page 3 / 5



# CERTIFICATE

No: 000237/04 - Annex No 1

## Test Reports:

- Nemko Canada Inc.: HS3128\_HSC3020C EN50130-4 Report 351820-2TRFEMC, 31 August 2018
- Nemko Canada Inc.: HS3128\_HSC3020CP EN50130-4 Report 351713-2TRFEMC, 20 June 2018
- Telefication: 180600139-002-Ver.2.00, 21 December 2018
- Telefication: 180600139-003-Ver 1.00, 04 December 2018
- Telefication: 180600139-001-Ver.3.00, 18 April 2019
- Telefication: 180600139-ENV-Ver.1.00, 03 December 2018

## Applied Standards

### EN 50130-4+A1 October, 2014

Alarm systems - Part 4: Electromagnetic compatibility - Product family standard: Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems

### EN 50131-1+A1+A2+A3 June, 2020

Alarm systems - Intrusion and hold-up systems - Part 1: System requirements

### EN 50136-1+A1 November, 2018

Alarm systems - Alarm transmission systems and equipment - Part 1: General requirements for alarm transmission systems

### EN 50130-5 June, 2011

Alarm systems - Part 5: Environmental test methods

# CERTIFICATE

No: 000237/04 - Annex No 2

## Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

## Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

## DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.